

House \_\_\_\_\_ Amendment NO. \_\_\_\_\_

Offered By

1 AMEND House Committee Substitute for Senate Bill No. 1039, Page 13, Section 226.224, Line 3,  
2 by inserting the following after all of said section and line:

3  
4 "640.144. 1. All community water systems shall be required to create a valve inspection  
5 program that includes:

6 (1) Inspection of all valves every ten years;

7 (2) Scheduled repair or replacement of broken valves; and

8 (3) Within five years of August 28, 2020, identification of each shut-off valve location using  
9 a geographic information system or an alternative physical mapping system that accurately  
10 identifies the location of each valve.

11 2. All community water systems shall be required to create a hydrant inspection program  
12 that includes:

13 (1) [~~Annual~~] Scheduled testing of every hydrant in the community water system;

14 (2) Scheduled repair or replacement of broken hydrants;

15 (3) A plan to flush every hydrant and dead-end main;

16 (4) Maintenance of records of inspections, tests, and flushings for six years; and

17 (5) Within five years of August 28, 2020, identification of each hydrant location using a  
18 geographic information system or an alternative physical mapping system that accurately identifies  
19 the location of each hydrant.

20 3. The provisions of this section shall not apply to any state parks, cities with a population  
21 of more than thirty thousand inhabitants, a county with a charter form of government and with more  
22 than six hundred thousand but fewer than seven hundred thousand inhabitants, a county with a  
23 charter form of government and with more than nine hundred fifty thousand inhabitants, or a public  
24 service commission regulated utility with more than thirty thousand customers."; and

25  
26 Further amend said bill by amending the title, enacting clause, and intersectional references  
27 accordingly.

Action Taken \_\_\_\_\_ Date \_\_\_\_\_